

11/10/2023

## DECLARATION OF PERFORMANCE

ID: 47417

## 1. Product categories:

VILPE® Roof Pass-Throughs, Intake vents, Exhaust ventilation pipes, Ventilation pipes, Solar pass-throughs, Ridge ventilation, Alipai ventilation, Roof hatches and EPDM roof pass-through sealants

## 2. Type, batch or serial number or any other element allowing identification of the product:

On Labels and markings on the product.

## 3. Intended use or uses of the construction product:

VILPE® products are intended to be used as a part of ventilation system. Pass throughs are selected according to the roofing material. Other products intended use is explained in the Installation, operating and maintenance instructions.

## 4. Name, registered trade name or registered trademark and contact address of the manufacturer:

VILPE Oy  
Kauppatie 9  
FI-65610 Mustasaari  
www.vilpe.com

## 5. External quality control:

Eurofins Expert Services Oy - Quality control contract A-1021-19



[VILPE.COM](https://www.vilpe.com)



11/10/2023

## 6. Declared performance:

Characteristics	Evaluation	Performance declaration
UV resistance	EN 13523-10 (2000h) EN 10169 Table 8	Class R <sub>UV4</sub>
Watertight installation	EN 1027	Watertight
Fan and exhaust pipe performance	ISO 5801 ISO 5219	Performance data found in product pages at: <a href="http://www.vilpe.com/en/">www.vilpe.com/en/</a>
Reaction to Fire	EN 13501-1	Class E

This declaration of performance is issued under the sole responsibility of the manufacturer identified in point 4.  
Signed for and on behalf of the manufacturer by:



Tuomas Saikkonen, CEO  
11/10/2023 Mustasaari, Finland

**VILPE Oy**  
Kauppatie 9 65610 Mustasaari

