

Determination of the filtration performance of air filter VILPE Wiwe 100 suodatinpussi according to EN ISO 16890:2016



Requested by **VILPE Oy**
Martin Granö
Kauppatie 9
65610 Mustasaari, Finland
martin.grano@vilpe.com

Order ref. Martin Granö, 17.6.2022, EF4APT220037-02

Contact person **Eurofins Expert Services Oy**
Antti Korhonen
Tekniikantie 4 B
02150 Espoo, Finland
AnttiKorhonen@eurofins.fi

Assignment	Determination of the filtration performance of air filter VILPE Wiwe 100 suodatinpussi according to EN ISO 16890:2016
Sample details	The customer delivered ten air filters, from which eight was randomly selected for tests and are detailed in Appendix 1. Picture from filter adapting panel is presented in Appendix 9. The sample were received 12.7.2022. The measurements were made 2. - 9.11.2022.
Methods	The tests were made according to EN ISO 16890:2016 standard series /1, 2, 3 and 4/ Deviating from standard, test air flow rate was lower than 0.25 m³/s. The filter discharging treatment were made by exposing it to isopropanol vapor. The purity of the isopropanol used in the test was ≥99.5 %. The air flow rates were measured with a calibrated orifice plate with corner pressure tappings. The instruments used in the measurements are presented in Appendix 8.
	FINAS Finnish Accreditation Service has accredited our laboratory (T001, Appendix 1.08, Eurofins Expert Services Oy) to perform measurements according to EN ISO 16890:2016 standard series.
Results	A summary of the test results, fractional efficiency values and calculation of the particulate matter efficiencies (ePM) are presented in Appendix 1. Initial and conditioned fractional efficiency measurement results are presented in accordance with EN ISO 16890-2:2016 and EN ISO 16890-4:2016 in Appendix 2. Air flow rate and pressure drop measurement results are presented in accordance with EN ISO 16890-2:2016 in Appendix 3. Test aerosol particle numbers measured in determination of initial fractional efficiency is presented in Appendix 4 and for conditioned fractional efficiency in Appendix 5. Normalized downstream particle size distributions and measured efficiencies in standardized environments are presented in Appendix 6. The EN ISO 16890-1:2016 guideline for interpretation of test reports is presented in Appendix 7. The measurements have been made so that the accuracy demands set in the standard ISO 16890-2 are fulfilled, i.e. pressure difference accuracy ±2 Pa in the range 0 - 70 Pa, above 70 Pa 3 % of the measured value, uncertainty of air flow rate ≤ 5 % at a 95 % confidence level. The results are only valid for the tested filter sample.

References

- /1/ EN ISO 16890-1:2016. Air filters for general ventilation - Part 1: Technical specifications, requirements and classification system based upon particulate matter efficiency (ePM)
- /2/ EN ISO 16890-2:2022. Air filters for general ventilation - Part 2: Measurement of fractional efficiency and air flow resistance
- /3/ EN ISO 16890-3:2016. Air filters for general ventilation - Part 3: Determination of the gravimetric efficiency and the air flow resistance versus the mass of test dust captured
- /4/ EN ISO 16890-4:2022. Air filters for general ventilation - Part 4: Conditioning method to determine the minimum fractional test efficiency

Espoo, 9.11.2022

Antti Korhonen

Expert

Appendices

9

Distribution

Customer, electronically approved



The results are only valid for the tested sample(s).
This report may be published in its entirety, parts of it only with a written permission by Eurofins

EN ISO 16890-1:2016 Air Filter Test Results

GENERAL

Test no.:	224700	Device receiving date:	12.7.2022
Test requested by:	VILPE Oy	Date of test:	2. - 9.11.2022
Device delivered by:	VILPE Oy	Operator:	RB

DEVICE TESTED

Model	Manufacturer	Construction 8 units tested in parallel
VILPE Wiwe 100 suodatinpussi	VILPE Oy	
Type of medium Synthetic	Net effective filtering area -	Filter dimensions (inner/outer x depth) Ø 92/54 mm x 180 mm

TEST DATA

Test air flow rate 40 dm ³ /s	Test air temperature 22 - 23 °C	Test air relative humidity 44 - 46 %	Test aerosol DEHS and KCl	Loading dust -
---	------------------------------------	---	------------------------------	-------------------



CONDITIONING ENVIRONMENT

Time of conditioning 24 h	Room temperature 18 - 18 °C	Room relative humidity 55 - 60 %	Barometric pressure 100.1 - 100.7 kPa	Evaporated IPA amount 163 g
------------------------------	--------------------------------	-------------------------------------	--	--------------------------------

RESULTS

Initial pressure drop 4 Pa	Initial gravimetric arrestance	ePM ₁ , min 23 %	ePM _{2.5} , min 36 %	ISO rating
Final test pressure drop -	Test dust capacity	ePM ₁ 35 %	ePM _{2.5} 47 %	ePM ₁₀ 77 %

Remarks: Eight filters were tested in parallel. Air flow rate through one filter is 5 l/s



NOTE: The results of this test relate only to the test device in the condition stated herein. The performance results cannot be themselves be quantitatively applied to predict filtration performance in all "real life" environments.



The results are only valid for the tested sample(s).
This report may be published in its entirety, parts of it only with a written permission by Eurofins

Fractional efficiency values

EN ISO 16890-1,2,4:2016

Air filter: VILPE Wiwe 100 suodatinpussi

Test no.: 224700

 Test aerosols: DEHS (0.3 - 1 μm) and KCl (1 - 10 μm)

 Air flow rate: 40 dm^3/s

OPC Bin, i	Particle size			Fractional efficiency		
	Δd_i μm	\bar{d}_i μm	$\Delta \ln d_i$ μm	E_i %	$E_{D,i}$ %	$E_{A,i}$ %
1	0.30 - 0.41	0.35	0.31237	41	20	30
2	0.41 - 0.55	0.47	0.29376	46	22	34
3	0.55 - 0.70	0.62	0.24116	51	25	38
4	0.70 - 1.00	0.84	0.35667	58	28	43
5	1.00 - 1.30	1.14	0.26236	78	54	66
6	1.30 - 1.60	1.44	0.20764	82	58	70
7	1.60 - 2.20	1.88	0.31845	86	62	74
8	2.20 - 3.00	2.57	0.31015	91	72	81
9	3.00 - 4.00	3.46	0.28768	95	80	87
10	4.00 - 5.50	4.69	0.31845	98	89	93
11	5.50 - 7.00	6.20	0.24116	99	93	96
12	7.00 - 10.00	8.37	0.35667	99	96	98

Symbols and units
 Δd_i Particle size range i , μm
 \bar{d}_i Geometric mean diameter of a size range i , μm
 $\Delta \ln d_i$ Logarithmic width of particle diameter size range i
 E_i Initial fractional efficiency of particle size range i of the untreated and unloaded filter element, %

 $E_{D,i}$ Fractional efficiency of particle size range i of the filter element after an artificial conditioning step, %

 $E_{A,i}$ Average fractional efficiency of particle size range i , %


The results are only valid for the tested sample(s).
 This report may be published in its entirety, parts of it only with a written permission by Eurofins

**Calculation of the particulate matter efficiencies (ePM)
EN ISO 16890-1:2016**

Air filter: VILPE Wiwe 100 suodatinpussi

Test no.: 224700

Test aerosols: DEHS (0.3 - 1 μm) and KCl (1 - 10 μm)

Air flow rate: 40 dm^3/s

OPC Bin, i	Particle size			$q_{3u}(\bar{d}_i)$	$q_{3u}(\bar{d}_i) * \Delta \ln d_i$	Urban size distribution			$ePM_{x, min}$ %	ePM_x %
	Δd_i μm	\bar{d}_i μm	$\Delta \ln d_i$ μm			$E_{D,i} * q_{3u}(\bar{d}_i)$ $* \Delta \ln d_i$	$E_{A,i} * q_{3u}(\bar{d}_i)$ $* \Delta \ln d_i$			
1	0.30 - 0.41	0.35	0.31237	0.225685	0.070498	0.014262	0.021490			
2	0.41 - 0.55	0.47	0.29376	0.197321	0.057965	0.012664	0.019715			
3	0.55 - 0.70	0.62	0.24116	0.158372	0.038193	0.009699	0.014610			
4	0.70 - 1.00	0.84	0.35667	0.115223	0.041097	0.011555	0.017691	$ePM_{1, min}$	ePM_1	
Σ line 1-4				0.207754	0.048180	0.073506	23	35		
5	1.00 - 1.30	1.14	0.26236	0.085032	0.022309	0.012019	0.014752			
6	1.30 - 1.60	1.44	0.20764	0.076177	0.015817	0.009143	0.011047			
7	1.60 - 2.20	1.88	0.31845	0.080218	0.025546	0.015952	0.018948			
8	2.20 - 3.00	2.57	0.31015	0.099839	0.030966	0.022210	0.025164	$ePM_{2,5, min}$	$ePM_{2,5}$	
Σ line 1-8				0.302392	0.107505	0.143417	36	47		

OPC Bin, i	Particle size			$q_{3r}(\bar{d}_i)$	$q_{3r}(\bar{d}_i) * \Delta \ln d_i$	Rural size distribution			ePM_x %	
	Δd_i μm	\bar{d}_i μm	$\Delta \ln d_i$ μm			$E_{A,i} * q_{3r}(\bar{d}_i)$ $* \Delta \ln d_i$				
1	0.30 - 0.41	0.35	0.31237	0.093806	0.029303				0.008932	
2	0.41 - 0.55	0.47	0.29376	0.083478	0.024522				0.008340	
3	0.55 - 0.70	0.62	0.24116	0.074324	0.017924				0.006856	
4	0.70 - 1.00	0.84	0.35667	0.070137	0.025016				0.010769	
5	1.00 - 1.30	1.14	0.26236	0.076281	0.020013				0.013234	
6	1.30 - 1.60	1.44	0.20764	0.088326	0.018340				0.012808	
7	1.60 - 2.20	1.88	0.31845	0.108042	0.034406				0.025521	
8	2.20 - 3.00	2.57	0.31015	0.137262	0.042573				0.034597	
9	3.00 - 4.00	3.46	0.28768	0.167084	0.048067				0.042041	
10	4.00 - 5.50	4.69	0.31845	0.195424	0.062233				0.058038	
11	5.50 - 7.00	6.20	0.24116	0.216707	0.052261				0.050203	
12	7.00 - 10.00	8.37	0.35667	0.231428	0.082545				0.080531	
Σ line 1-12				0.457204					0.351871	77

Symbols and units

Δd_i Particle size range i , μm

\bar{d}_i Geometric mean diameter of a size range i , μm

$\Delta \ln d_i$ Logarithmic width of particle diameter size range i

$q_{3u}(\bar{d}_i)$ Discrete urban particle volume distribution, dimensionless

$q_{3r}(\bar{d}_i)$ Discrete rural particle volume distribution, dimensionless

$E_{D,i}$ Fractional efficiency of particle size range i of the filter element after an artificial conditioning step, %

$E_{A,i}$ Average fractional efficiency of particle size range i , %

$ePM_{x, min}$ Minimum particulate matter efficiency value of the conditioned filter, %

ePM_x Particulate matter efficiency, %




The results are only valid for the tested sample(s).
This report may be published in its entirety, parts of it only with a written permission by Eurofins

**Initial and conditioned fractional efficiency
EN ISO 16890-2,4:2016**

Air filter: VILPE Wiwe 100 suodatinpussi

Test no.: 224700

Test aerosols: DEHS (0.3 - 1 µm) and KCl (1 - 10 µm)

 Air flow rate: 40 dm³/s


Particle size Δd_i µm	\bar{d}_i µm	Fractional efficiency and upstream concentration					
		Initial, q _v = 100 % %	#/dm ³	Conditioned, q _v = 100 % %	#/dm ³	Conditioned, q _v = 50 % %	#/dm ³
0.30 - 0.41	0.35	40.7	36 588	20.2	24 221	24.2	27 858
0.41 - 0.55	0.47	46.2	23 802	21.8	15 939	25.4	18 279
0.55 - 0.70	0.62	51.1	15 947	25.4	10 868	30.9	12 444
0.70 - 1.00	0.84	58.0	18 143	28.1	12 545	36.7	14 518
1.00 - 1.30	1.14	78.4	5 482	53.9	8 824		
1.30 - 1.60	1.44	81.9	5 240	57.8	8 382		
1.60 - 2.20	1.88	85.9	7 207	62.4	11 337		
2.20 - 3.00	2.57	90.8	5 310	71.7	8 314		
3.00 - 4.00	3.46	94.9	4 390	80.0	6 904		
4.00 - 5.50	4.69	97.8	2 486	88.8	3 901		
5.50 - 7.00	6.20	99.1	759	93.1	1 105		
7.00 - 10.00	8.37	99.3	768	95.9	1 095		
DEHS concentration		122 303		83 493			
KCl concentration		107 568		168 584			
Pressure drop		4 Pa		5 Pa			

 Particle counter coincidence value is 250 000 #/dm³
Symbols and units
 Δd_i Particle size range, µm

 \bar{d}_i Geometric mean diameter of a size range i, µm

 q_v Air flow rate at filter


The results are only valid for the tested sample(s).
This report may be published in its entirety, parts of it only with a written permission by Eurofins

**Air flow rate and pressure drop
EN ISO 16890-2:2016**

Air filter: VILPE Wiwe 100 suodatinpussi

Test no.: 224700

 Air flow rate: 40 dm³/s

Date	Loaded dust g	t _f °C	Calibrated orifice plate ¹⁾			t °C	φ %	p _a kPa	ρ kg/m ³	q _v dm ³ /s	q _{vsingle} dm ³ /s	Filter Δp Pa	Δp _{1,20} Pa	% of rated air flow
			p _{sf} kPa	Δp _f Pa	q _m kg/s									
Clean Filter														
2.11.2022	-	21.6	-0.020	141	0.072	22.8	45.0	101.9	1.194	60	7.5	7	7	150 %
"	-	21.3	-0.020	97	0.060	22.6	44.5	101.9	1.194	50	6.2	5	5	125 %
"	-	21.4	-0.020	62	0.048	22.6	45.2	101.9	1.195	40	5.0	4	4	100 %
"	-	21.6	-0.015	35	0.036	22.6	45.3	101.9	1.194	30	3.7	3	3	75 %
"	-	21.7	-0.015	15	0.024	22.6	45.1	101.9	1.194	20	2.5	2	2	50 %
Clean filter pressure drop is proportional to (q _v) ⁿ , where n = 1.106														
Conditioned filter														
9.11.2022	-	22.4	-0.020	63	0.048	22.4	45.8	100.7	1.181	40	5.0	5	5	100 %
"	-	22.5	-0.015	15	0.024	22.5	45.8	100.7	1.180	20	2.5	2	2	50 %

Symbols and units

m _{tot}	Cumulative mass of dust fed to filter, g	t _f	Temperature at air flow meter, °C
p _a	Absolute air pressure upstream of filter, kPa	ρ	Air density upstream of filter, kg/m ³
p _{sf}	Air flow meter static pressure, kPa	φ	Relative humidity upstream of filter, %
q _m	Mass flow rate, kg/s	Δp	Measured filter pressure drop, Pa
q _v	Air flow rate at filter, dm ³ /s	Δp _f	Air flow meter differential pressure, Pa
q _{vsingle}	Air flow rate through one filter, dm ³ /s	Δp _{1,20}	Filter pressure drop at air density 1.20 kg/m ³ , Pa
t	Temperature upstream of filter, °C		

¹⁾ Orifice plate dimensions

 Duct dimensions: 610 mm x 610 mm
 Orifice diameter: 90 mm


The results are only valid for the tested sample(s).
 This report may be published in its entirety, parts of it only with a written permission by Eurofins

Correlation data for initial efficiency
EN ISO 16890-2:2016

Air filter: VILPE Wiwe 100 suodatinpussi

Test no.: 224700

Test aerosols: DEHS (0.3 - 1 µm) and KCl (1 - 10 µm)

Air flow rate: 40 dm³/s

OPC Bin, i	\bar{d}_i µm	Initial and final background					
		$U_{B,c,b}$	$U_{B,c,f}$	$U_{B,c}$	$D_{B,c,b}$	$D_{B,c,f}$	$D_{B,c}$
1	0.35	3	4	3.5	2	5	3.5
2	0.47	1	0	0.5	1	0	0.5
3	0.62	0	0	0	0	0	0
4	0.84	0	1	0.5	0	0	0
5	1.14	0	0	0	0	0	0
6	1.44	0	0	0	0	0	0
7	1.88	0	0	0	1	0	0.5
8	2.57	0	0	0	0	0	0
9	3.46	0	0	0	0	0	0
10	4.69	0	0	0	0	0	0
11	6.20	0	0	0	0	0	0
12	8.37	0	0	0	0	0	0

All data shown is the number of particle counts for 60 seconds

OPC Bin, i	\bar{d}_i µm	Upstream correlation (five measurements)					Downstream correlation (five measurements)					
		1	2	3	4	5	$U_{c,tot}$	1	2	3	5	$D_{c,tot}$
1	0.35	33666	34695	35558	36585	37461	177965	31110	32174	33007	33964	34365 164620
2	0.47	21515	22427	23216	23496	24239	114893	22784	23406	24419	24760	25352 120721
3	0.62	14835	15231	15674	15844	16359	77943	15102	15313	15718	16199	16415 78747
4	0.84	16684	17495	17666	17920	18541	88306	16410	16936	17573	17757	17992 86668
5	1.14	5357	5734	5804	5856	6055	28806	5108	5547	5690	5916	5908 28169
6	1.44	5129	5387	5551	5744	5822	27633	4259	4642	4950	5021	5084 23956
7	1.88	6988	7343	7779	7702	7982	37794	6528	6937	7351	7650	7784 36250
8	2.57	5122	5376	5514	5675	5769	27456	4811	5309	5604	5791	5803 27318
9	3.46	4213	4431	4513	4651	4679	22487	3872	4324	4471	4620	4705 21992
10	4.69	2466	2566	2612	2729	2678	13051	2388	2508	2674	2721	2785 13076
11	6.20	775	783	790	841	789	3978	743	847	816	937	854 4197
12	8.37	736	777	853	821	840	4027	792	786	854	817	858 4107

All data shown is the number of particle counts for 60 seconds

OPC Bin, i	\bar{d}_i µm	Correlation ratios (five measurements)						Uncertainty limits			
		R_1	R_2	R_3	R_4	R_5	R_{avg}	Pass/Fail	δ_c	e_c	Pass/Fail
1	0.35	0.924	0.927	0.928	0.928	0.917	0.925	Pass	0.0047	0.0058	Pass
2	0.47	1.059	1.044	1.052	1.054	1.046	1.051	Pass	0.0062	0.0076	Pass
3	0.62	1.018	1.005	1.003	1.022	1.003	1.010	Pass	0.0091	0.0113	Pass
4	0.84	0.984	0.968	0.995	0.991	0.970	0.982	Pass	0.0120	0.0148	Pass
5	1.14	0.954	0.967	0.980	1.010	0.976	0.977	Pass	0.0210	0.0260	Pass
6	1.44	0.830	0.862	0.892	0.874	0.873	0.866	Pass	0.0227	0.0282	Pass
7	1.88	0.934	0.945	0.945	0.993	0.975	0.958	Pass	0.0248	0.0307	Pass
8	2.57	0.939	0.988	1.016	1.020	1.006	0.994	Pass	0.0331	0.0411	Pass
9	3.46	0.919	0.976	0.991	0.993	1.006	0.977	Pass	0.0340	0.0422	Pass
10	4.69	0.968	0.977	1.024	0.997	1.040	1.001	Pass	0.0303	0.0376	Pass
11	6.20	0.959	1.082	1.033	1.114	1.082	1.054	Pass	0.0607	0.0753	Pass
12	8.37	1.076	1.012	1.001	0.995	1.021	1.021	Pass	0.0323	0.0402	Pass

Symbols and units

\bar{d}_i	Geometric mean diameter of a size range i, µm	$D_{B,c}$	Downstream background count average for correlation
$U_{B,c,b}$	Upstream beginning background count for correlation	$U_{c,tot}$	Total upstream particle counts
$U_{B,c,f}$	Upstream final background count	$D_{c,tot}$	Total downstream particle counts
$U_{B,c}$	Upstream background count average for correlation	R_{avg}	Average correlation ratio
$D_{B,c,b}$	Downstream beginning background count for correlation	δ_c	Standard deviation of the correlation values
$D_{B,c,f}$	Downstream final background count	e_c	Uncertainty at 95 % confidence interval for correlation values



The results are only valid for the tested sample(s).
This report may be published in its entirety, parts of it only with a written permission by Eurofins

Initial efficiency data

EN ISO 16890-2:2016

Air filter: VILPE Wiwe 100 suodatinpussi

Test no.: 224700

Test aerosols: DEHS (0.3 - 1 µm) and KCl (1 - 10 µm)

 Air flow rate: 40 dm³/s

OPC Bin, i	\bar{d}_i µm	Initial and final background					
		$U_{B,e,b}$	$U_{B,e,f}$	$U_{B,e}$	$D_{B,e,b}$	$D_{B,e,f}$	$D_{B,e}$
1	0.35	2	2	2	5	6	5.5
2	0.47	2	0	1	1	0	0.5
3	0.62	0	0	0	0	0	0
4	0.84	0	1	0.5	0	0	0
5	1.14	0	0	0	0	0	0
6	1.44	1	1	1	0	0	0
7	1.88	0	0	0	0	0	0
8	2.57	0	0	0	0	0	0
9	3.46	0	0	0	0	0	0
10	4.69	0	0	0	0	0	0
11	6.20	0	0	0	0	0	0
12	8.37	0	0	0	0	0	0

All data shown is the number of particle counts for 60 seconds

OPC Bin, i	\bar{d}_i µm	Upstream efficiency (five measurements)					Downstream efficiency (five measurements)					$D_{e,tot}$
		1	2	3	4	5	$U_{e,tot}$	1	2	3	4	
1	0.35	36276	36581	36561	36772	36751	182941	19993	20103	20363	19709	20123
2	0.47	23471	23720	23687	24155	23976	119009	13368	13465	13507	13345	13621
3	0.62	15838	15701	15903	16152	16140	79734	7967	7797	7845	7825	7950
4	0.84	17895	18024	18230	18394	18173	90716	7347	7445	7433	7557	7636
5	1.14	4893	5409	5585	5794	5727	27408	1028	1088	1197	1243	1241
6	1.44	4539	5145	5496	5534	5487	26201	728	784	843	909	849
7	1.88	6462	6980	7405	7511	7675	36033	881	876	1017	1037	1061
8	2.57	4698	5204	5514	5471	5662	26549	411	493	500	519	505
9	3.46	3875	4307	4487	4615	4666	21950	194	205	254	234	209
10	4.69	2224	2541	2539	2583	2543	12430	45	55	55	74	51
11	6.20	691	799	761	739	806	3796	10	9	4	8	6
12	8.37	672	805	785	785	793	3840	5	4	9	5	6

All data shown is the number of particle counts for 60 seconds

OPC Bin, i	\bar{d}_i µm	Observed penetration (five measurements)					
		P_{o1}	P_{o2}	P_{o3}	P_{o4}	P_{o5}	P_o
1	0.35	0.551	0.550	0.557	0.536	0.548	0.548
2	0.47	0.570	0.568	0.570	0.552	0.568	0.566
3	0.62	0.503	0.497	0.493	0.484	0.493	0.494
4	0.84	0.411	0.413	0.408	0.411	0.420	0.412
5	1.14	0.210	0.201	0.214	0.215	0.217	0.211
6	1.44	0.160	0.152	0.153	0.164	0.155	0.157
7	1.88	0.136	0.126	0.137	0.138	0.138	0.135
8	2.57	0.087	0.095	0.091	0.095	0.089	0.091
9	3.46	0.050	0.048	0.057	0.051	0.045	0.050
10	4.69	0.020	0.022	0.022	0.029	0.020	0.022
11	6.20	0.014	0.011	0.005	0.011	0.007	0.010
12	8.37	0.007	0.005	0.011	0.006	0.008	0.008

OPC Bin, i	\bar{d}_i µm	Penetration data reduction			Uncertainty limits		Efficiency %
		P	δ	e	Static	Dynamic	
1	0.35	0.593	0.009	0.011	0.05	0.041	Pass 40.7
2	0.47	0.538	0.008	0.010	0.05	0.038	Pass 46.2
3	0.62	0.489	0.008	0.010	0.05	0.034	Pass 51.1
4	0.84	0.420	0.007	0.009	0.05	0.029	Pass 58.0
5	1.14	0.216	0.008	0.010	0.05	0.015	Pass 78.4
6	1.44	0.181	0.008	0.009	0.05	0.013	Pass 81.9
7	1.88	0.141	0.007	0.008	0.05	0.010	Pass 85.9
8	2.57	0.092	0.005	0.006	0.05	0.006	Pass 90.8
9	3.46	0.051	0.005	0.006	0.05	0.008	Pass 94.9
10	4.69	0.022	0.004	0.004	0.05	0.003	Pass 97.8
11	6.20	0.009	0.003	0.004	0.05	0.002	Pass 99.1
12	8.37	0.007	0.002	0.003	0.05	0.001	Pass 99.3

Symbols and units

\bar{d}_i	Geometric mean diameter of a size range i, µm	$U_{e,tot}$	Total upstream particle counts
$U_{B,e,b}$	Upstream beginning background count for penetration	$D_{e,tot}$	Total downstream particle counts
$U_{B,e,f}$	Upstream final background count	P_o	Observed penetration, -
$U_{B,e}$	Upstream background count average for penetration	P	Penetration, -
$D_{B,e,b}$	Downstream beginning background count for penetration	δ_o	Standard deviation of the observed penetration
$D_{B,e,f}$	Downstream final background count	δ	Standard deviation of the penetration
$D_{B,e}$	Downstream background count average for penetration	e	Uncertainty at 95 % confidence interval for penetration values



The results are only valid for the tested sample(s).
This report may be published in its entirety, parts of it only with a written permission by Eurofins

Correlation data for conditioned efficiency
EN ISO 16890-2:2016

Air filter: VILPE Wiwe 100 suodatinpussi

Test no.: 224700

Test aerosols: DEHS (0.3 - 1 µm) and KCl (1 - 10 µm)

Air flow rate: 40 dm³/s

OPC Bin. i	\bar{d}_i µm	Initial and final background					
		$U_{B,c,b}$	$U_{B,c,f}$	$U_{B,c}$	$D_{B,c,b}$	$D_{B,c,f}$	$D_{B,c}$
1	0.35	0	0	0	0	0	0
2	0.47	0	0	0	0	0	0
3	0.62	0	0	0	0	0	0
4	0.84	0	0	0	0	0	0
5	1.14	29	15	22	43	23	33
6	1.44	60	27	43.5	32	27	29.5
7	1.88	42	23	32.5	52	32	42
8	2.57	9	8	8.5	18	5	11.5
9	3.46	0	3	1.5	5	5	5
10	4.69	1	2	1.5	2	0	1
11	6.20	0	0	0	0	0	0
12	8.37	0	0	0	0	0	0

All data shown is the number of particle counts for 60 seconds

OPC Bin. i	\bar{d}_i µm	Upstream correlation (five measurements)					Downstream correlation (five measurements)						
		1	2	3	4	5	$U_{c,tot}$	1	2	3	5	$D_{c,tot}$	
1	0.35	18743	20000	21216	21706	21816	103481	17397	18511	19457	19868	19845	95078
2	0.47	12192	12954	13971	14089	14357	67563	12688	13375	13977	14402	14558	69000
3	0.62	8596	8893	9291	9510	9855	46145	8452	9023	9418	9607	9896	46396
4	0.84	9769	10480	11130	11383	11463	54225	9463	10067	10624	10784	11263	52201
5	1.14	9504	9433	9443	9479	9533	47392	9737	9432	9458	9272	9283	47182
6	1.44	9098	9208	9164	8952	9115	45537	8622	8375	8379	8274	8284	41934
7	1.88	12337	12336	12611	12224	12703	62211	12523	12269	12126	12078	12014	61010
8	2.57	8809	8928	8886	8765	9120	44508	9399	9211	9233	9193	9182	46218
9	3.46	7307	7561	7393	7284	7756	37301	7566	7334	7459	7417	7440	37216
10	4.69	4035	4239	4077	4130	4188	20669	4376	4219	4330	4378	4343	21646
11	6.20	1169	1197	1251	1214	1261	6092	1391	1304	1303	1303	1237	6538
12	8.37	1183	1276	1237	1183	1298	6177	1318	1257	1291	1323	1286	6475

All data shown is the number of particle counts for 60 seconds

OPC Bin. i	\bar{d}_i µm	Correlation ratios (five measurements)						Pass/Fail	Uncertainty limits		
		R_1	R_2	R_3	R_4	R_5	R_{avg}		δ_c	e_c	Pass/Fail
1	0.35	0.928	0.926	0.917	0.915	0.910	0.919	Pass	0.0076	0.0094	Pass
2	0.47	1.041	1.032	1.000	1.022	1.014	1.022	Pass	0.0157	0.0195	Pass
3	0.62	0.983	1.015	1.014	1.010	1.004	1.005	Pass	0.0129	0.0160	Pass
4	0.84	0.969	0.961	0.955	0.947	0.983	0.963	Pass	0.0136	0.0168	Pass
5	1.14	1.025	1.000	1.002	0.978	0.974	0.996	Pass	0.0204	0.0254	Pass
6	1.44	0.948	0.910	0.914	0.924	0.909	0.921	Pass	0.0162	0.0201	Pass
7	1.88	1.015	0.995	0.962	0.988	0.946	0.981	Pass	0.0275	0.0341	Pass
8	2.57	1.067	1.032	1.039	1.049	1.007	1.039	Pass	0.0222	0.0275	Pass
9	3.46	1.035	0.970	1.009	1.018	0.959	0.998	Pass	0.0325	0.0403	Pass
10	4.69	1.085	0.995	1.062	1.060	1.037	1.048	Pass	0.0338	0.0420	Pass
11	6.20	1.190	1.089	1.042	1.073	0.981	1.075	Pass	0.0764	0.0949	Pass
12	8.37	1.114	0.985	1.044	1.118	0.991	1.050	Pass	0.0643	0.0798	Pass

Symbols and units

\bar{d}_i	Geometric mean diameter of a size range i, µm	$D_{B,c}$	Downstream background count average for correlation
$U_{B,c,b}$	Upstream beginning background count for correlation	$U_{c,tot}$	Total upstream particle counts
$U_{B,c,f}$	Upstream final background count	$D_{c,tot}$	Total of the downstream particle counts
$U_{B,c}$	Upstream background count average for correlation	R_{avg}	Average correlation ratio
$D_{B,c,b}$	Downstream beginning background count for correlation	δ_c	Standard deviation of the correlation values
$D_{B,c,f}$	Downstream final background count	e_c	Uncertainty at 95 % confidence interval for correlation values



Conditioned efficiency data
EN ISO 16890-2:2016

Air filter: VILPE Wiwe 100 suodatinpussi
 Test no.: 224700
 Test aerosols: DEHS (0.3 - 1 µm) and KCl (1 - 10 µm)
 Air flow rate: 40 dm³/s

OPC Bin, i	\bar{d}_i µm	Initial and final background					
		$U_{B,e,b}$	$U_{B,e,f}$	$U_{B,e}$	$D_{B,e,b}$	$D_{B,e,f}$	$D_{B,e}$
1	0.35	0	0	0	0	0	0
2	0.47	0	0	0	0	0	0
3	0.62	0	0	0	0	0	0
4	0.84	0	0	0	0	0	0
5	1.14	0	0	0	0	0	0
6	1.44	0	0	0	0	0	0
7	1.88	0	0	0	0	0	0
8	2.57	0	0	0	0	0	0
9	3.46	0	0	0	0	0	0
10	4.69	0	0	0	0	0	0
11	6.20	0	0	0	0	0	0
12	8.37	0	0	0	0	0	0

All data shown is the number of particle counts for 60 seconds

OPC Bin, i	\bar{d}_i µm	Upstream efficiency (five measurements)					Downstream efficiency (five measurements)					
		1	2	3	4	5	$U_{e,tot}$	1	2	3	5	
1	0.35	25084	24421	24042	23912	23644	121103	19398	18335	17559	16966	16600 88858
2	0.47	16639	16222	15679	15522	15633	79695	13933	13010	12339	12246	12165 63693
3	0.62	11241	11064	10774	10682	10580	54341	8902	8174	8004	7867	7824 40771
4	0.84	13000	12783	12494	12276	12170	62723	9385	8956	8596	8351	8147 43435
5	1.14	7979	8582	9073	9219	9266	44119	3636	3903	4088	4367	4274 20268
6	1.44	7623	8332	8766	8469	8721	41911	2852	3105	3369	3452	3525 16303
7	1.88	10249	11108	11799	11669	11860	56685	3797	4026	4304	4354	4404 20885
8	2.57	7606	8097	8590	8521	8758	41572	2203	2389	2470	2604	2545 12211
9	3.46	6300	6902	7073	7083	7161	34519	1174	1350	1433	1442	1491 6890
10	4.69	3601	3806	3997	4049	4050	19503	428	428	485	457	500 2298
11	6.20	1003	1095	1223	1088	1118	5527	85	83	80	91	71 410
12	8.37	1010	1082	1080	1118	1184	5474	38	42	58	54	46 238

All data shown is the number of particle counts for 60 seconds

OPC Bin, i	\bar{d}_i µm	Observed penetration (five measurements)					
		P_{01}	P_{02}	P_{03}	P_{04}	P_{05}	P_o
1	0.35	0.773	0.751	0.730	0.710	0.702	0.733
2	0.47	0.837	0.802	0.787	0.789	0.778	0.799
3	0.62	0.792	0.739	0.743	0.736	0.740	0.750
4	0.84	0.722	0.701	0.688	0.680	0.669	0.692
5	1.14	0.456	0.455	0.451	0.474	0.461	0.459
6	1.44	0.374	0.373	0.384	0.408	0.404	0.389
7	1.88	0.370	0.362	0.365	0.373	0.371	0.368
8	2.57	0.290	0.295	0.288	0.306	0.291	0.294
9	3.46	0.186	0.196	0.203	0.204	0.208	0.199
10	4.69	0.119	0.112	0.121	0.113	0.123	0.118
11	6.20	0.085	0.076	0.065	0.084	0.064	0.075
12	8.37	0.038	0.039	0.054	0.048	0.039	0.043

OPC Bin, i	\bar{d}_i µm	Penetration data reduction			Uncertainty limits		Efficiency %
		P	δ	e	Static	Dynamic	
1	0.35	0.798	0.033	0.041	0.05	0.056	Pass 20.2
2	0.47	0.782	0.026	0.032	0.05	0.055	Pass 21.8
3	0.62	0.746	0.025	0.031	0.05	0.052	Pass 25.4
4	0.84	0.719	0.023	0.029	0.05	0.050	Pass 28.1
5	1.14	0.461	0.013	0.016	0.05	0.032	Pass 53.9
6	1.44	0.422	0.019	0.024	0.05	0.030	Pass 57.8
7	1.88	0.376	0.012	0.014	0.05	0.026	Pass 62.4
8	2.57	0.283	0.009	0.011	0.05	0.020	Pass 71.7
9	3.46	0.200	0.011	0.013	0.05	0.030	Pass 80.0
10	4.69	0.112	0.006	0.007	0.05	0.017	Pass 88.8
11	6.20	0.069	0.010	0.013	0.05	0.014	Pass 93.1
12	8.37	0.041	0.007	0.009	0.05	0.008	Pass 95.9

Symbols and units

\bar{d}_i	Geometric mean diameter of a size range i, µm	$U_{e,tot}$	Total upstream particle counts
$U_{B,e,b}$	Upstream beginning background count for penetration	$D_{e,tot}$	Total downstream particle counts
$U_{B,e,f}$	Upstream final background count	P_o	Observed penetration, -
$U_{B,e}$	Upstream background count average for penetration	P	Penetration, -
$D_{B,e,b}$	Downstream beginning background count for penetration	δ_o	Standard deviation of the observed penetration
$D_{B,e,f}$	Downstream final background count	δ	Standard deviation of the penetration
$D_{B,e}$	Downstream background count average for penetration	e	Uncertainty at 95 % confidence interval for penetration values





FINAS
 Finnish Accreditation Service
 T001 (EN ISO/IEC 17025)

The results are only valid for the tested sample(s).
 This report may be published in its entirety, parts of it only with a written permission by Eurofins

Normalized downstream particle size distribution and measured efficiencies
EN ISO 16890-1,2,4:2016

Air filter: VILPE Wive 100 suodatinpussi
Test no.: 224700
Test aerosols: DEHS (0.3 - 1 μm) and KCl (1 - 10 μm)
Air flow rate: 40 dm^3/s



Particle size Δd_i μm	\bar{d}_i μm	$\Delta \ln d_i$ μm	Urban size distribution				Rural size distribution				Fractional efficiency		
			$q_{3u}(\bar{d}_i)$	$q_{3u}(\bar{d}_i)^* / \Delta \ln d_i$	$E_i * q_{3u}(\bar{d}_i) / \Delta \ln d_i$	$E_{D,i} * q_{3u}(\bar{d}_i) / \Delta \ln d_i$	$q_{3r}(\bar{d}_i)$	$q_{3r}(\bar{d}_i)^* / \Delta \ln d_i$	$E_i * q_{3r}(\bar{d}_i) / \Delta \ln d_i$	$E_{D,i} * q_{3r}(\bar{d}_i) / \Delta \ln d_i$	Initial, E_i %	Conditioned $E_{D,i}$ %	Average $E_{A,i}$ %
0.30 - 0.41	0.35	0.31237	0.22568	0.070498	0.028718	0.014262	0.021490	0.093806	0.029303	0.008932	41	20	30
0.41 - 0.55	0.47	0.29376	0.19732	0.057965	0.026766	0.012664	0.019715	0.083478	0.024522	0.008340	46	22	34
0.55 - 0.70	0.62	0.24116	0.15837	0.038193	0.019520	0.009699	0.014610	0.074324	0.017924	0.006856	51	25	38
0.70 - 1.00	0.84	0.35667	0.11522	0.041097	0.023827	0.011555	0.017691	0.070137	0.025016	0.010769	58	28	43
1.00 - 1.30	1.14	0.26236	0.08503	0.022309	0.017485	0.012019	0.014752	0.076281	0.020013	0.013234	78	54	66
1.30 - 1.60	1.44	0.20764	0.07618	0.015817	0.012950	0.009143	0.011047	0.088326	0.018340	0.012808	82	58	70
1.60 - 2.20	1.88	0.31845	0.08022	0.025546	0.021945	0.015952	0.018948	0.108042	0.034406	0.025521	86	62	74
2.20 - 3.00	2.57	0.31015	0.09984	0.030966	0.028118	0.022210	0.025164	0.137262	0.042573	0.034597	91	72	81
3.00 - 4.00	3.46	0.28768	0.12688	0.036500	0.034633	0.029215	0.031924	0.167084	0.048067	0.042041	95	80	87
4.00 - 5.50	4.69	0.31845	0.15556	0.049537	0.048427	0.043968	0.046197	0.195424	0.062233	0.058038	98	89	93
5.50 - 7.00	6.20	0.24116	0.17757	0.042823	0.042422	0.039850	0.041136	0.216707	0.052261	0.050203	99	93	96
7.00 - 10.00	8.37	0.35667	0.19157	0.068329	0.067823	0.065502	0.066662	0.231428	0.082545	0.080531	99	96	98

Symbols and units

- Δd_i Particle size range, μm
- \bar{d}_i Geometric mean diameter of a size range i , μm
- $\Delta \ln d_i$ Logarithmic width of particle diameter size range i
- $q_{3u}(\bar{d}_i)$ Discrete urban particle volume distribution, dimensionless
- $q_{3r}(\bar{d}_i)$ Discrete rural particle volume distribution, dimensionless
- E_i Initial fractional efficiency of particle size range i of the untreated and unloaded filter element, %
- $E_{D,i}$ Fractional efficiency of particle size range i of the filter element after an artificial conditioning step, %
- $E_{A,i}$ Average fractional efficiency of particle size range i , %
- $\epsilon\text{PM}_{x,\text{ini}}$ Initial particulate matter efficiency value of the clean filter, %
- $\epsilon\text{PM}_{x,\text{min}}$ Minimum particulate matter efficiency value of the conditioned filter, %
- ϵPM_x Particulate matter efficiency, %

Particulate matter efficiencies		
$\epsilon\text{PM}_{1,\text{ini}}$	$\epsilon\text{PM}_{1,\text{min}}$	ϵPM_1
48 %	23 %	35 %
$\epsilon\text{PM}_{2.5,\text{ini}}$	$\epsilon\text{PM}_{2.5,\text{min}}$	$\epsilon\text{PM}_{2.5}$
59 %	36 %	47 %
$\epsilon\text{PM}_{10,\text{ini}}$	$\epsilon\text{PM}_{10,\text{min}}$	ϵPM_{10}
84 %	69 %	77 %
		ISO ϵPM_{10} 75 %



The results are only valid for the tested sample(s).
This report may be published in its entirety, parts of it only with a written permission by Eurofins

**The interpretation of test reports
ISO 16890-1:2016**

This brief review of the test procedures, including those for addressing the testing of electrostatic charged filters, is provided for those unfamiliar with the procedures of this series of ISO standards. It is intended to assist in understanding and interpreting the results in the test report/summary (for further details of procedures, the full ISO 16890 document series shall be consulted).

Air filters may rely on the effects of passive static electric charges on the fibres to achieve high efficiencies, particularly in the initial stages of their working life. Environmental factors encountered in service may affect the action of these electric charges so that the initial efficiency may drop substantially after an initial period of service. This could be offset or countered by an increase in efficiency ("mechanical efficiency") as dust deposits build up. The reported, untreated and conditioned (discharged) efficiency shows the extent of the electrical charge effect on initial performance and indicates the potential loss of particle removal efficiency when the charge effect is completely removed and when, at the same time, there is no compensating increase of the mechanical efficiency.

These test results should not be assumed to represent the filter performance in all possible environmental conditions or to represent all possible "real-life" behaviour.

Instruments used in the test				
Instrument	Type code	Serial number	Calibration date	Used
Micromanometer	Furness C012	209103	15.7.2022	X
	Furness C012	1211165	15.7.2022	X
	Micatrone MF-PD	32760-068	15.7.2022	X
Barometer	Vaisala PTB330	F4340001	18.7.2022	X
Hygrometer	Vaisala HMT333	D3940024	13.12.2021	X
Temperature meter	Agilent 34970A	MY44034623	3.9.2021	X
Balance	Precisa XB10200D-IP65	5300037	11.1.2022	-
	DFWATEX2GD-1	93411584	11.1.2022	X
Particle counter	TSI 3330	3330152501	11.1.2022	X
	TSI 3330	3330160801	12.1.2022	X
DEHS aerosol generator	ISO 16890-2:2016	-	-	X
KCl aerosol generator	TSI 8108	8108153201	-	X
Dust feeder	TOPAS SAG 440	440 13 03 406	3.10.2022	-
Orifice plate	Ø 216 mm / (610 x 610) mm	-	7.12.2020	-
	Ø 272 mm / (610 x 610) mm	-	7.12.2020	-
	Ø 90 mm / (610 x 610) mm	-	7.12.2020	X



Picture 1. Filter installation in adapting panel allowing eight filter units parallel testing. Any possible leakages around the filter were duct taped.